


REPLY TO BIDDER'S QUERIES

 <b>Bid Document for the Supply, Installation and Commissioning of Car and Car Cum Bus Dispensers alongwith Comprehensive AMC for Kanpur, Unmao, Bareilly and Jhansi</b>					<b>Bid Document No.: CUCL/C&amp;P/TEN2223/16 dated 12.04.2023 (E-Tender No. 54813)</b>
Sr. No.	Tender Clause No. / Annexures	Page No.	Subject	Bidder's Queries / Observation/Comments	CUCL Response
1	4.16	122 of 148	ESD button to be mounted on both side of the dispenser front panel and shall be easily accessible during emergencies.	Our OEM make Design For ESD button to be mounted on Side panel of dispenser Cabinet. Request to consider to Same	Tender condition prevails
2	Clause - 4.37 Fill Hose & Fill Nozzle	124 of 148	Hose length : 4 meter-from nozzle to Break away coupling and 0.5 meter from break away coupling to dispenser fitting.	Min. Length required for Proper working of Hi-mast is 1800 mm as per our standard frame, so kindly accept hose length (for both hose - main & vent) from breakaway to dispenser length 1.8 Mtr. & Nozzle to breakaway 3 Mtr.	Tender condition prevails
3	4.40 (B)	126 of 148	Mass Flow Meter (Only Coriolis based Emerson:micromotion CNG 50 or E&H CNG Mass flow meter will be accepted)  Mass flow meter with integral display unit shall be provided to ensure high accuracy and direct mass flow measurement approved for custody transfer metering of CNG at each of the refueling hose.	Kindly include make KG Mass Flow Meter in the approved vendor list. make Mass Flow meter are specially designed for CNG application and is part of our standard design and already under use in IGL, MGL, BGRL, IOCL, HPCL, Gail Gas & India.  OEM make mass flow meter all the readings are indicated in the main display panel on the front which is easily accessible. Request you to kindly accept the same and include Bidder Make FM in approved make List.	Tender Condition Prevails
4	4.40 (D)	126 of 148	3 Way Valve	Kindly include Hy-lok make 3-Way valves too, As Fittings and 2 Way valve of same make is already given in approved Vendor List.	Tender Condition Prevails

Bidder are required to submit the "REPLY TO BIDDER'S QUERIES" alongwith the bid duly signed & stamped.

  
 2 of 02/12/2023