

REPLY TO BIDDER'S QUERIES					
Bid Document for the Procurement of Commercial Diaphragm Meters for Kanpur, Unnao, Bareilly and Jhansi on ARC Basis					
Sr. No.	Tender Clause No. / Annexures	Page No.	Subject	Bidder's Queries/ Observation/Comments	Bid Document No.: CUGL/C&P/TEN2324/21 dated 27.04.2023 (E-Tender No. 54959)
1	First Page & IFB	BID Document No	BID Document No	We have received the Query from bank for the preparation EMD for mentioning the Correct Tender No as there is a 2 different no is mentioned. Please confirm the correct tender no. for making the EMD and correct tender documents.	Bid Document No.: CUGL/C&P/TEN2324/21 dated 27.04.2023 (E-Tender No. 54959)
2	IFB	Point No 6	Bid Security /EMD	2 different tender/Bid No mentioned in the Tender documents & received query from Bank also for the same. Please note that PBG processing time from bank is minimum 3-4 Days. In the short time of submission it is not possible. We request you to kindly extend the bid due date by 1 week.	Refer Corrigendum-1
3	SCC	Clause No-4	Delivery Schedule:- 8 weeks from the date of LOI	Delivery period of 8 weeks is too less as all these items required are imported and not manufactured in India. The delivery period should be a minimum of 16 - 20 weeks	Tender Condition Prevails
4	SCC	Clause No-4	Delivery Schedule:- 8 weeks from the date of LOI	Since the tender quantity is very small thus entire quantity should be taken in a single lot. If not then at least G 10, G 16 and G 25 diaphragm meters should compulsorily be taken in single lot only.	Accepted
5	Technical Datasheet	Technical Datasheet	Technical Datasheet-Commercial Diaphragm Gas Meter	Restriction office is not required and is never supplied and used by any CGD companies. The restriction office is generally supplied with an RPD meter. Kindly remove the requirement of restriction office from the diaphragm gas meter.	Accepted
6	Technical Datasheet	Technical Datasheet	Technical Datasheet-Commercial Diaphragm Gas Meter- Centre to Centre Distance	Generally the centre-to-centre distance is defined by the manufacturer. In the present case, we are supplying G 10 with center to center distance of 280 mm as against your requirement of 250 mm. Kindly accept Centre to center distance for G 10 as 280 mm.	Tender Condition Prevails
7	Technical Datasheet	Technical Datasheet	Pressure Drop - 2mbar	Pressure drop for G16 & G25 should be less than 3mbar.	Tender Condition Prevails
8	IFB	IFB	B Bid Submission Date	We need time 5-7 days for the tender preparation from the pre bid query reply received. We request you to kindly extend the bid due date by a minimum of 1 week.	Refer Corrigendum-1
9				We are writing in reference to Tender no. CUGL/C&P/TEN2223/21 dated 27/04/2023, which concerns the procurement of Commercial Diaphragm Meters for Kanpur, Unnao, Bareilly, and Jhansi. Regarding the BEC-Technical Criteria Sr.no 2, which states that "The bidder must have successfully supplied Commercial Meters (Diaphragm) as per below table in a single order to any City Gas Distribution Company in India in the last seven years from the bid due date," We, bidder, would like to express our interest in this tender. Our company has been awarded the IGL tender for Commercial and Industrial Gas Meters, and our OEM Zenner has supplied gas meters worldwide. We kindly request the opportunity to submit a competitive and aggressive bid with our credentials. We assure you that our products and services are of the utmost quality and excellence, and we look forward to your kind consideration.	Tender Condition Prevails
10				We are interested in participating in your above tender. However few important documents from our OEM are still awaited and the same are expected to be received till 10.05.2023	Refer Corrigendum-1
				We therefore request CUGL to extend the due date of reference tender for 2 weeks time to enable us to participate in tender.	

Bidder are required to submit the "REPLY TO BIDDER'S QUERIES" alongwith the bid duly signed & stamped.

